

# Feasibility Study of Hybrid Photovoltaic (PV)-Generator Set Power Plant at Palm Oil Mill

Ramadian Saputra

Universitas Islam Negeri Sultan Syarif Kasim Riau  
Department of Electrical Engineering  
Jl. HR. Soebrantas Simpang Baru,  
Pekanbaru, 28293, Indonesia  
[ramadiansaputra00@gmail.com](mailto:ramadiansaputra00@gmail.com)

Marhama Jelita

Universitas Islam Negeri Sultan Syarif Kasim Riau  
Department of Electrical Engineering  
Jl. HR. Soebrantas Simpang Baru,  
Pekanbaru, 28293, Indonesia  
[marhamajelita@uin-suska.ac.id](mailto:marhamajelita@uin-suska.ac.id)

Article history: Received Maret 13, 2024 | Revised April 22, 2024 | Accepted April 23, 2024

**Abstract** – Kuko Palm Oil Mill, currently not interconnected with PLN electricity, relies on diesel-fueled generators of 1100 kVA and 650 kVA to meet its electrical needs. To reduce diesel consumption, a Hybrid Power Plant (PLTH) system comprising generators, batteries, and Photovoltaic (PV) panels is proposed. Optimization studies, evaluating technical and economic feasibility, are conducted using HOMER software. Optimal PLTH configuration includes 8,727 kW PV, 500 kW generator, 1,000 kW generator, 25,708 battery units, and 1,481 kW converter. PLTH generates 14,339,116 kWh/year, fulfilling PKS electricity requirements. Economic analysis yields NPC of Rp356,000,000,000, initial investment of Rp77,400,000,000, operation and maintenance costs of Rp21,600,000,000, and LCOE of Rp3,147/kWh. IRR stands at 22%, NPV is positive at Rp124,000,000,000, with a 3.5-year capital return. These results indicate PLTH feasibility both technically and economically.

**Keywords:** Feasibility, Hybrid Power Plant, Optimization, Photovoltaic (PV), Generator Set



[Creative Commons Attribution-NonCommercial-ShareAlike 4.0 International License.](https://creativecommons.org/licenses/by-nc-sa/4.0/)

## I. INTRODUCTION

Along with the massive development of technology and the rapid development of the times, it has an impact on the greater need for energy. PLN data states that in the past 6 years, electricity sales by PLN nationally have increased every year by 3.5% with a significant increase in the number of customers of 3.7 million customers. In 2020, PLN was recorded selling electricity to customers in various sectors with a total of 241,140 GWh [1]. One of the largest PLN customer sectors enjoying electricity is the industrial sector. The industrial sector has the second largest energy demand after the household sector. Since 2011-2019, the industrial sector has consistently used electrical energy with an annual increase of 4-6% for annual national electricity consumption. Even in 2020, the industrial sector used 30% of the total electricity sold by PLN [1].

The industrial sector that is among the largest electricity customers and uses a large amount of electricity is the palm oil industry. This is because Indonesia is the largest producer and country with the

largest palm oil industry in the world, which has a total land area of 14.3 million ha of palm oil land. The region with the largest palm oil industry in Indonesia is Riau Province. Riau has 2.7 million ha of oil palm land or equivalent to 19% of the total oil palm land area in Indonesia. One of the palm oil companies that has a large land area and the largest production in Riau is PT Duta Palma Nusantara PKS Kuko. PKS Kuko Palm Oil Mill has a total land area of 14,257 ha of land with a total of 168,980 oil palm trees and a total electricity demand of 1,800,597 kWh / year to serve the electricity needs of offices, production and mess staff employees. Electricity needs for offices and mess staff employees are supplied by generators with a capacity of 1100 kVA, while electricity needs for production that operates from 06.00 - 18.00 WIB are supplied by generators with a capacity of 650 kVA. In addition to the high price of diesel fuel, PKS also has standards for the use of fossil fuels on their impact on the environment. Therefore, PKS is also trying to reduce the use of diesel fuel. The Genset Power Plant at Kuko PKS using diesel fuel has a high price problem, in 2021 IDR 10,726/liter [2] and increased to IDR 16,000/liter in 2023 [3].

The problem of diesel-fueled generator power plants in Kuko PKS has been studied by research [2]. Research [2] which conducted a study on the potential of bioethanol by utilizing oil palm sap waste from the results of oil palm replanting as a generator fuel at Kuko PKS into electrical energy. The results of the research study [2] found that the potential for electrical energy from the utilization of palm oil sap waste obtained from E0 compared to E10 and E100 is with the potential of E10 of 34,166,278.6 kWh while for E100 of 22,628,077.7 kWh. The results of the research study [2] E10 has greater potential with a content of 10% ethanol and 90% diesel. These results show that the percentage of diesel fuel use is still quite large, therefore the use of diesel fuel is replaced by utilizing renewable potential sources at Kuko PKS. Kuko PKS has renewable energy potential including biomass and solar energy. The potential of solar energy in Kuko PKS is 4.8 kWh/m<sup>2</sup> or equivalent to 112,000 GWp [4]. PKS has the potential in the form of solar energy

which can be a Solar Power Plant (PLTS) as a source of electricity at PKS.

The potential of solar energy can be simulated using the Hybrid Optimization Model for Electric Renewables (HOMER Pro) application. In addition to knowing the potential of solar energy, HOMER Pro also serves to simulate the hybrid power generation system to determine the most optimal system [5] [6]. The HOMER Pro application is used to analyze the economic aspects of hybrid power plants, which include the price of electricity from generating sources (LCOE), payback period analysis, and the cash flow rate of the investment built (NPC) [7] [8]. Based on its function, the HOMER Pro application can be used for technical and economic simulation of hybrid power plants. Several studies have examined the feasibility between PLTD with generators, off-grid PLTS and PLTH from PLTS and PLTD. Research [9] has examined the performance of the PLTD generator against load changes, the results obtained by increasing the load affect the capacity of the generator and the use of fuel is increasing up to 1140 liters per 24 hours according to the generator's working time and periodic maintenance is required every 250 hours. Research [10] has examined the economics of designing off-grid solar power plants at a workshop with several scenarios. The result of research [10] is the lowest NPV value of - Rp252,285,665 which means the investment does not return capital. Solar Power Plants (PLTS) can be hybridized with various other power plants. Several studies have conducted studies on this hybrid power plant. Research [11] conducted the feasibility of a hybrid power generation system (PLTH) between PLTD and PLTS using the HOMER simulation method to get the optimal scenario of the plant. This research produced the best scheme with electricity generated by PLTS as much as 1,374,514 kWh / year and PLTD 879,024 kWh / year where PLTS contributed 61% and PLTD 39% to meet the load.

Seeing the large use of diesel as a generator fuel [9], and the loss if only using off-grid PLTS as a stand alone [10], the authors propose a solution based on research [11] to hybridize between PLTD and add a new type of generator by utilizing the renewable energy potential of solar energy for off-grid Solar Power Plants (PLTS). PLTS in this study is designed a hybrid system with generators because there is still no electricity supply from the PLN network which results in the availability of electricity at the PKS only being supplied from two diesel-fueled generators with a capacity of 1100 kVA and 650 kVA so that other available energy sources are needed to reduce the use of diesel fuel.

This study will examine the most optimal Hybrid Power Plant (PLTH) system between a 1100 kVA diesel power plant, a 650 kVA generator, and an off-grid solar power plant using HOMER Pro software and then examine the feasibility of a hybrid power

plant (PLTH) between PV and generator in technical and economic aspects at an oil palm mill.

## II. METHOD

At PT Duta Palma Nusantara PKS Kuko has not been interconnected with the PLN electricity network, therefore the electricity supply is supplied by two generators with a capacity of 1100 kVA and 650 kVA fueled by diesel. The high price of diesel fuel makes PKS want to reduce the operation of generators to minimize the use of diesel fuel. In this study, to reduce the use of diesel fuel, a solution is proposed, namely replacing the 650 kVA generator with a solar power plant so that it becomes a hybrid power plant and electricity is supplied by these two plants. Before implementing a hybrid between the two plants, it is necessary to carry out optimization to see the best scenario of PLTH and feasibility tests, namely from the technical and economic aspects of PLTH.

This research is a simulation by utilizing HOMER (Hybrid Optimization Model for Electric Renewable) Pro [12] software by designing a hybrid power plant (PLTH) between off-grid solar power plants and diesel power plants with generators. HOMER Pro will optimize the generation system and economic analysis of the Hybrid Power Plant (PLTH) system. This research is quantitative research and uses secondary data from research [2] in the form of load or energy consumption, resource assessment and specifications of generators and data from simulation software.

### A. Research Flowchart

The following are the steps or stages carried out by the author to obtain the desired results in the study. The research stages are presented in the form of a diagram which can be seen in Figure 1 below.




Figure 1. Research diagram

B. Data Collection

1. Site Selection of PT Duta Palma Nusantara PKS Kuko

The location used in the study was taken from research [2] which is located at PT Duta Palma Nusantara PKS Kuko, Kuantan Singingi Regency, Riau Province. This PT is located with coordinates 101° 32'30"- 101° 43'00' East and 0° 30'30"- 0° 42'40'. With latitude and longitude - 0.5798798426457958,101.58075293891874. This data is taken using the coordinate points on Google Maps. Later the latitude and longitude coordinate points will be inputted into the HOMER Pro simulation software.

2. Electricity Demand Load Data for Production PT Duta Palma Nusantara PKS Kuko

Load or energy consumption data at PT Duta Palma PKS Kuko is secondary data taken from research [2] can be seen in Table 1.

Table 1. Electricity Demand Data of PT Duta Palma Nusantara PKS Kuko

Years	Electricity Demand Per Year (kWh)	Average Electricity Demand Per Month (kWh)
2021	1,771,160	198,680
2020	1,800,597	208,480
2019	2,531,656	201,812
2018	2,178,964	214,676

Load demand data is the average monthly data for each year. The data will then be input to the simulation software and assumed to be the same every hour of the day.

3. Specification of PT Duta Palma Nusantara PKS Kuko Genset [2]

The specifications of the generator at PT Duta Palma Nusantara PKS Kuko can be seen in Table 2 and Table 3.

Table 2. 1100 kVA generator set specifications

Specification	Description
Manufacturer	Cummins
Model	QST 30 G4
Engine Power Output at rated rpm	970kWm 1300 HP
Total Displacement	30,480 L
Fuel Consumption at full load	202 L/h
Dimensions (L x W x H)	4400 x 1776 x 2341 mm

The generator specification data is needed for input to the HOMER Pro simulation software, which will then be hybridized with solar power plants.

Table 3. 650 kVA generator set specifications

Specification	Description
Manufacturer	Caterpillar
Model	C18DEAP
Cooling System	Engine Coolant Capacity 20,8L
Combustion Air Inlet Flow Rate	35.8 m <sup>3</sup> /min
Fuel Consumption at full load	133 L/h
Heat Rejection to Exhaust (Total)	27 kW

4. Assessment Resource

Site assessment data in the form of resource assessment is data provided by the HOMER Pro software, this data is obtained after inputting the location through coordinate points that have been obtained from research can be seen in Table 4.

Table 4. Global Horizontal Solar Irradiation

Month	Clearness Index	Daily Radiation (kWh/m <sup>2</sup> /day)
January	0.401	4.051
February	0.439	4.574
March	0.409	4.296
April	0.427	4.345
May	0.433	4.161
June	0.455	4.220
July	0.432	4.072
August	0.431	4.275
September	0.396	4.089
October	0.394	4.082
November	0.395	4.994
December	0.388	3.857

Global Horizontal Irradiation (GHI) data is data in 2023 which is useful for knowing the potential of solar energy at the location so that it is possible to know whether solar power plants are feasible to build at the location. The average solar radiation at the location is 4.17 kWh/m<sup>2</sup>/day.

5. Equipment Cost

The costs of the equipment used can be seen in Table 5.

Table 5. Hybrid Generation System Cost

Tools and Materials	Price
Diesel fuel	Rp16,000.00 / Liter
570 Wp PV	Rp2,058,409.69
1 kW converter	Rp4,963,000.00
1 unit battery	Rp1,500,000.00

Table 5 is the cost of the hybrid generation system, for maintenance costs is 10% of the price of equipment for PV, Converter and Battery.

C. Configuration of Hybrid Power Plant (PLTH) System

The configuration of the hybrid power plant (PLTH) system in this research can be seen in Figure 2.




Figure 2. PLTH configuration in HOMER Pro

The configuration of the generating system is a hybrid between a diesel power plant with a generator and an off-grid solar power plant. The components that are input to the HOMER Pro software are

1. 650 kVA generator set
2. 1100 kVA generator set
3. PV Module
4. Converter
5. Battery

The capacity of the PV, converter and battery will be generated after optimization in the simulation software to find the best results.

D. Optimization of Hybrid Power Generation System with HOMER Pro

Optimization is carried out using HOMER Pro software which is useful for simulation, optimization and sensitivity analysis [12]. The software will perform calculations to find the best system scenario of a hybrid power plant (PLTH) based on technical and economic aspects [7]. The best results obtained after optimization will show the performance of the PLTH between PV-generator set that works to meet the load at the PKS.

E. Technical Calculation of Hybrid Power Plant (PLTH)

Technical calculations are carried out in the HOMER Pro software, the software will calculate based on the best optimization results so that it will display the division of labor of each plant to generate electricity. The results obtained from optimization in the form of :

1. Power plant electricity production
2. Capacity of PV
3. Battery capacity
4. Converter capacity
5. Total fuel consumption of generator set

F. Economic Calculation of Hybrid Power Plant (PLTH)

The output of the simulation using HOMER Pro software is an economic analysis in the form of NPC, LCOE, payback period, investment costs and operating costs. From these output parameters, it can be seen whether the proposed system is feasible or not.

1. ]-=[Net Present Cost (NPC)

Net Present Cost or NPC can be defined as the total cost of all costs incurred for investment in the length of use, including initial investment funds, tool replacement costs, operation and maintenance, fuel costs, and other costs that may arise during the project. The equation used by HOMER Pro in calculating NPC is as follows [13].

$$C_{NPC} = \frac{C_{ann, tot}}{CRF(i, Rproj)} \quad (1)$$

Description :

- $C_{ann, tot}$  = Total Cost/year (IDR/Year)
- CRF = Capital Recovery Factor
- I = Interest Rate (in per cent %)
- R project : Lifecycle Project (25-30 years)

2. Life Cycle Cost of Energy (LCOE)

LCOE or Life Cost of Energy is the ratio between the total annual cost of the system and the energy produced in the same time period. If observed further, the cost of PLTS is influenced by several factors including the initial investment cost which is quite expensive but there is no need for fuel expenditure, followed by low operational and maintenance costs and knowable energy costs, thus affecting the difference between the cost of PLTS plants compared to other conventional plants [14]. The LCOE value can be calculated with the equation :

$$COE = \frac{total\ annualized\ cost}{consumption\ energy\ (\frac{kWh}{year})} \quad (2)$$

Description :

- COE = Cost of Energy (Rp)
- Total Annualized Cost = Total annual cost (Rp)
- Consumption Energy = Energy used (kWh/year)

3. Initial Capital

Initial capital is the initial investment cost for the construction of a power plant [15] In this hybrid design research, a PLTS system with a generator is designed, therefore important components in this hybrid design include solar modules, inverters and generators as generating components. Initial cost can be calculated with the equation :

$$Initial\ capital\ cost = cost\ (PV\ modules + Inverters + Battery + genset\ fuel) \quad (3)$$

4. O&M (Operation and Maintenance) Cost

O&M costs are annual costs that must be incurred for complete plant operations with maintenance to prevent or repair damage [15]. Annual operation and maintenance costs can be calculated by summing up all variables including maintenance costs and replacement of tools or components, more details of O&M costs can be calculated by the equation:

$$O\&M\ Cost\ per\ Year = O\&M\ Plant + Replacement \quad (4)$$

Description :

O&M Plant = Plant Operation and Maintenance Cost (Rp/Year)  
 Replacement = Component Replacement Costs (Rp/Year)

end of the project period. The payback period value affects the investment value, when the investment value is large but the project income is small, the project is said to be unfeasible [18] the payback period can be calculated using the equation [19] :

$$Payback\ period = \frac{System\ installation\ capital}{Annual\ savings} \quad (6)$$

G. Feasibility Standard for Hybrid Power Plant (PLTH)

1. Technical Feasibility

PLTH is said to be technically feasible if it is able to meet the load requirements at the PKS. If the results of the simulation produce electricity in excess of the PKS electricity needs in accordance with table 1, then PLTH can be said to be feasible.

2. Economic Feasibility

a. IRR (Internal Rate of Return)

One of the feasibility parameters of a project is the capex value, which is the value of expenditure for purchases and maintenance during the project. This capex value is interconnected with the IRR value, the greater the IRR value, the smaller the capex *II* value and as long as the IRR value is positive, the project can be said to be feasible when it exceeds the bank interest rate of 5.75% [16]. The IRR value can be calculated using the following equation [17].

$$IRR = i_t + \frac{NPV_1}{NPV_1 - NPV_2} (i_2 - i_1) \quad (5)$$

Description

$i_1$  = 1st interest rate  
 $i_2$  = 2nd interest rate  
 $NPV_1$  = NPV at interest rate  $i_1$   
 $NPV_2$  = NPV at interest rate  $i_2$

b. Payback Period

Payback period can be defined as the length of the payback period in a certain time. The value of the payback period or return of capital must be smaller than the life of the project so that the project can be said to be feasible when the capital returns before the

Description :

Payback period = Payback period (Years)  
 Installation Capital = Total Initial Investment Cost (Rp)  
 Annual savings = Annual Savings

c. Net Present Value (NPV)

Net Present Value (NPV) is a method in engineering economics to calculate the difference between the value of the investment made and the cash value in the future. If the future net cash value is positive or  $> 0$ , it means that the project is profitable and feasible. Conversely, if the NPV value  $< 0$  then the project is losing money. NPV can be calculated with the following equation [20].

$$NPV = \sum_{t=1}^n \frac{NCF_t}{(1-i)^t} - II \quad (7)$$

Description :

$NCF_t$  = Net Cash Flow for the year period  
 $II$  = Initial investment  
 $i$  = Discount  
 $t$  = Length of investment

III. RESULTS AND DISCUSSION

A. Hybrid Power Plant System Optimization

The optimization results will rank the best scenarios of the hybrid power plant system according to the technical aspects and performance of each component. The results of the optimization can be seen in Figure 3 and Figure 4

Architecture								
	PV (kW)	Genset 650 kVA (kW)	Genset 1100 kVA (kW)	1kWh LA	Converter (kW)	Dispatch		
	8,727	500	1,000	25,708	1,481	LF		
	7,162		1,000	5,116	1,459	CC		
		500	1,000	687	172	CC		
	31,256	500		36,436	1,386	LF		
	30,502			42,702	2,023	CC		

Figure 3. PLT Optimization Results per Category

Architecture										
					PV (kW)	Genset 650 kVA (kW)	Genset 1100 kVA (kW)	1kWh LA	Converter (kW)	Dispatch
					8,727	500	1,000	25,708	1,481	LF
					8,697	500	1,000	25,775	1,503	LF
					8,828	500	1,000	26,006	1,470	LF
					8,798	500	1,000	25,378	1,483	LF
					8,603	500	1,000	25,288	1,476	LF
					8,611	500	1,000	25,485	1,502	LF
					8,857	500	1,000	25,591	1,501	LF
					8,692	500	1,000	25,506	1,467	LF
					8,964	500	1,000	25,930	1,493	LF
					8,930	500	1,000	25,600	1,472	LF
					9,092	500	1,000	26,186	1,477	LF
					8,569	500	1,000	25,020	1,503	LF
					8,944	500	1,000	26,238	1,510	LF
					8,850	500	1,000	25,726	1,536	LF
					8,725	500	1,000	25,652	1,586	LF
					8,646	500	1,000	25,748	1,456	LF
					8,867	500	1,000	26,402	1,483	LF
					8,839	500	1,000	25,138	1,517	LF
					8,786	500	1,000	25,368	1,452	LF

Figure 4. Overall Optimization Results

From the results obtained in Figure 3 and Figure 4, the best scenario is a combination of PV with a capacity of 8,727 kW, 500 kW generator set, 1,000 kW generator set, 25,708 battery units, and 1,481 kW converter. This scenario is better than using only two generators in the current condition. This is influenced by several factors, namely, using PLTH as renewable energy is more optimal within 25 years than using diesel-fueled generators.

B. Technical Analysis of Hybrid Power Generation System (PLTH)

1. Electricity Production of Hybrid Power Plant (PLTH)

The electricity production generated from the best scenario between the solar power plant and two generators is as shown in Table 6 follows.

Generating Components	Electricity Production (kWh/year)	Percentage (%)
PV	12,592,701	87.8
650 kVA generator set	672,041	4.69
1100 kVA generator set	1,074,374	7.49
Total	14,339,116	100

From Table 6, it can be seen that the electricity production generated in one year is 14,339,116 kWh with each component, namely PV generating electrical

energy of 12,592,701 kWh / year, 650 kVA generator generating 672,041 kWh / year and 1100 kVA generator generating 1,074,374 kWh / year. PV contributes 87.8%, 650 kVA generator 4.69% and 1100 kVA generator 7.49% of the total 100% energy in one year. This means that the electricity generated by PLTH is sufficient for the electricity needs of the mill.

2. Comparison of Solar Fuel Usage of PLTH and PLTD

The results of the comparison of diesel fuel use between PLTH and PLTD can be seen in Table 7.

Table 7. Comparison of Solar Fuel Consumption

Plant Type	Solar Fuel Consumption Per Year (Liters)	Average daily diesel fuel consumption (Liters)
PLTH	467,047	1,280
PLTD	2,287,976	6,268

Table 7 is the result of the comparison of diesel fuel consumption between PLTH and PLTD. PLTH uses diesel fuel in one year around 467,047 liters, while if only using PLTD the amount of diesel fuel consumption is 2,287,967 liters. This means that if you use PLTH, PKS is able to save 1,820,929 liters of diesel in one year. If calculated with the price of industrial diesel in 2023, which is Rp16,000, PKS can save costs of Rp29,134,864,000.

C. Economic Analysis of Hybrid Power Plant (PLTH)



HOMER Pro software presents a comparison of the results between PLTH and only using PLTD.

The results of the comparison of the use of PLTD and PLTH from an economic perspective can be seen in Table 8.

Table 8. Summary of Power Plant and Solar PV Costs

Category	PLTD	PLTH
NPC	Rp480B	Rp356B
Initial Capital	Rp1.88	Rp77.4B
O&M	Rp37.0B/years	Rp21.8B/years
LCOE	Rp4,239/kWh	Rp3,147/kWh

Table 8 is the result of the comparison between PLTD and PLTH from the economic aspect. The factor that most influences the optimization results from the economic aspect is the NPC (Net Present Cost) value. The best scenario results from the smallest NPC value. PLTH produces an NPC value of Rp356,000,000,000 smaller than using only PLTD, which is Rp480,000,000,000. The NPC value of PLTH is able to save Rp124,000,000,000. The initial capital or initial investment value of PLTH is Rp77,400,000,000,000. The cost of operation and maintenance of PLTH, which is Rp21,600,000,000, is more efficient at Rp15,400,000,000 than using PLTD at a cost of Rp37,000,000,000. The price of electricity generated or LCOE from PLTH is IDR 3,147/kWh while for PLTD is IDR 4,239/kWh. From the economic aspect, the use of PLTH is more profitable if it is implemented than only using PLTD.

#### D. Feasibility Analysis of Hybrid Power Plant (PLTH)

##### 1. Technical Feasibility

The technical feasibility of producing a hybrid power plant (PLTH) can be seen in Table 9 below.

Table 9. Comparison of MCC Electricity Demand and PLTH Electricity Production

Electricity Demand Per Year (kWh)	Power Plant Electricity Production Per Year (kWh)
2,531,656	14,339,116

Based on Table 9, the electricity production generated by PLTH is 14,339,116 kWh in one year can meet the electricity needs of the PKS. From these results it can be said that PLTH is feasible from a technical aspect.

##### 2. Economic Feasibility

Economic metrics are parameters that can analyze the profitability of a project. There are three metric economic parameters, namely, Internal Rate of Return (IRR), Net Present Value (NPV), and Payback Period. The financial metrics results can be seen in Table 10.

Table 10. Economic feasibility of solar power plant

Internal Rate of Return (IRR)	Net Present Value (NPV)	Payback Period
22%	+Rp124B	3.5 Years

Table 10 shows the economic metrics of the hybrid power plant (PLTH), which obtained an IRR value of 22% and an NPV of +Rp124,000,000,000, with a payback period of 3.5 years. From the calculations carried out, it can be analyzed that if  $NPV > 0$  and IRR are positive, the investment will get a return (profit); otherwise, if it is negative, it can be concluded that the investment made will lose profit (loss). With the results obtained, IRR, NPV, and payback period are positive, so PLTH can be said to be feasible from an economic aspect [16] [18].

#### IV. CONCLUSION

Hybrid power plant (PLTH) at PT Duta Palma Nusantara PKS Kukuo with PV-genset configuration based on HOMER Pro simulation getting the most optimal results with PV components 8,727 kW, 500 kW generator, 1,000 kW generator, 25,708 battery units and 1,481 kW converter is the most optimal result. Using PLTH is able to reduce the use of diesel fuel by 1,820,929 liters of diesel in one year from previously using PLTD with diesel fuel consumption of 2,287,976 liters a year to 467,047 liters with PLTH for one year. PLTH can produce electricity in one year of 14,339,116 kWh in one year which has met the electricity needs of PKS by 2,531,656 kWh one year. While for the economic side, the NPC value of PLTH is Rp356,000,000,000, initial capital is Rp77,400,000,000, operation and maintenance costs are Rp21,600,000,000, and LCOE is Rp3,147/kWh. PLTH is more profitable in a project time of 25 years with an IRR value obtained of 22%, a positive NPV value of Rp124,000,000,000 and investment will be recouped within 3.5 years. Based on the results obtained through the HOMER Pro simulation, PLTH can be said to be feasible from the technical and economic aspects.

#### V. REFERENCES

- [1] Menteri Energi dan Sumber Daya Mineral Republik Indonesia, 'Rencana Usaha Penyediaan Tenaga Listrik (RUPTL) PT PLN (Persero) 2021-2030', 2021.
- [2] E. Y. Setiawan and M. Jelita, 'Potensi Listrik Dari Bioetanol Nira Kelapa Sawit Limbah Replanting Studi Kasus PT Duta Palma Nusantara PKS Kukuo, Kabupaten Kuantan Singingi, Riau', *SITEKIN*, vol. 19, no. 2, pp. 340–349, 2022.
- [3] Ri. Alfaridzi, 'Harga Solar 2023', PT. SHA Solo. Accessed: Dec. 19, 2023. [Online]. Available: <https://shasolo.com/harga-solar-industri-hari-ini-2023/>
- [4] S. Syafii, Y. Mayura, and M. Muhardika, 'Strategi Pembebanan PLTS Off Grid untuk Peningkatan Kontinuitas Suplai Energi Listrik', *Jurnal Rekayasa ElektriKa*, vol. 15, no. 3, Jan. 2020, doi: 10.17529/jre.v15i3.14793.
- [5] E. Kumolosari, Y. V. Yoanita, and S. T. Pinindriya, 'Optimasi Pembangkit Daya Hibrid Dengan Energi Terbarukan (Studi Kasus di Desa Koak NTT)', *Conference SENATIK STT*

- Adisutjipto Yogyakarta*, vol. 6, Dec. 2020, doi: 10.28989/senatik.v6i0.416.
- [6] Ibrahim and D. Rusirawan, 'Optimalisasi Sistem Mikrogrid Hibrida Berbasis Jarak Pagar menggunakan HOMER', *ELKOMIKA: Jurnal Teknik Energi Elektrik, Teknik Telekomunikasi, & Teknik Elektronika*, vol. 7, no. 2, p. 268, May 2019, doi: 10.26760/elkomika.v7i2.268.
- [7] R. S. Wahind, F. Anas, M. R. Afandi, and K. Anam, 'Analisis Perencanaan Sistem Pembangkit Listrik Tenaga Hybrid dengan Homer Pro di Pantai Liang Ambon Maluku', *Majalah Ilmiah Swara Patra*, vol. 13, no. 2, pp. 15–32, Sep. 2023, doi: 10.37525/sp/2023-2/453.
- [8] A. B. Pulungan and R. Afriyanti, 'Studi Ekonomi Solar Panel Pada Penetas Telur Itik Menggunakan Homer Pro Energy', *ELKOMIKA*, vol. 3, no. 1, pp. 241–248, 2022, doi: 10.24036/jtein.v3i1.236.
- [9] S. P. Pratama, W. Hayatullah, F. M. Yakut, and M. F. Umam, 'Analisa Performa Generator Set Diesel PLTD Terhadap Perubahan Beban di Pusat Pengembangan Sumber Daya Manusia Minyak dan Gas Bumi', *Majalah Ilmiah Swara Patra*, vol. 11, no. 1, Mar. 2021, doi: 10.37525/sp/2021-1/271.
- [10] D. P. I. P. Ariantika, I. N. Setiawan, and I. W. Sukerayasa, 'Analisa Ekonomi Rancangan PLTS Off-Grid Pada Adidaya Workshop', *Jurnal SPEKTRUM*, vol. 10, no. 3, 2023.
- [11] A. Soba, V. A. Suoth, and H. S. Kolibu, 'Optimasi Kapasitas Pembangkit Listrik Tenaga Hybrid (PLTH) di Pulau Bunaken Menggunakan Software HOMER', *Jurnal MIPA UNSRAT ONLINE*, vol. 8, no. 1, pp. 7–12, 2019.
- [12] O. A. Jaya, H. S. Kolibu, and V. A. Suoth, 'Desain Sistem Pembangkit Listrik Tenaga Hybrid Diesel Generator-PV Menggunakan Software HOMER (Studi Kasus: KM Barcelona 1 di Pelabuhan Manado)', *Jurnal MIPA UNSRAT Online*, vol. 8, no. 2, pp. 63–66, 2019, [Online]. Available: <http://ejournal.unsrat.ac.id/index.php/jmuo>
- [13] A. W. Akbar, N. Hiron, and N. Nadrotan, 'Perencanaan Sistem Pembangkit Listrik Dengan Sumber Energi Terbarukan (HOMER) Di Daerah Pesisir Pantai Pangandaran', *Journal Of Energy And Electrical Engineering (JEEE)*, vol. 01, no. 01, pp. 12–18, 2019.
- [14] A. Ariansyah, A. Hiendro, K. Hie Kwee, Z. Abidin, P. Studi Sarjana Teknik Elektro, and J. Teknik Elektro, 'Perancangan Energi Optimum Sistem PLTS Untuk Base Transceiver Station'.
- [15] P. Seminar and N. Mipa, 'Perancangan Pembangkit Listrik Tenaga Surya (PLTS) Berbasis HOMER di SMA Negeri 6 Surakarta Sebagai Sekolah Hemat Energi dan Ramah Lingkungan', 2019.
- [16] U. Masyarakat *et al.*, 'Rancangan Implementasi Pembangkit Listrik Tenaga Surya (PLTS) Skala Rumah Tangga menggunakan Software HOMER', *JURNAL SUSTAINABLE*, vol. 5, no. 02, 2016.
- [17] F. Hadiatna, D. Fauziah, and E. Syahirah, 'Studi Kelayakan Pembangkit Listrik Tenaga Hybrid Surya Bayu di Kota Bandung', *ELKOMIKA: Jurnal Teknik Energi Elektrik, Teknik Telekomunikasi, & Teknik Elektronika*, vol. 11, no. 3, p. 811, Jul. 2023, doi: 10.26760/elkomika.v11i3.811.
- [18] R. S. Ningsih, A. K. Mudzakir, and A. Rosyid, 'Analisis Kelayakan Finansial Usaha Perikanan Payang Jabur (Boat Seine) di Pelabuhan Perikanan Asemtoyong Kabupaten Pematang', *Journal of Fisheries Resources Utilization Management and Technology*, vol. 2, no. 3, pp. 223–232, 2013.
- [19] M. Giatrnan, *Ekonomi Teknik*. Jakarta, 2011.
- [20] I. N. Haq, J. Pradipta, M. R. S. Sheba, A. W. D. Persada, F. X. N. Soelami, and E. Leksono, 'Simulasi Energi dan Keekonomian Sistem Pembangkit Listrik Tenaga Surya (PLTS) untuk Fungsi Peak Load Shaving pada Bangunan di Lingkungan Kampus ITB', *Journal of Science and Applicative Technology*, vol. 5, no. 1, p. 179, May 2021, doi: 10.35472/jsat.v5i1.449.
- [21] D. A. Budiarta, S. Handoko, and A. A. Zahra, 'Analisis Ekonomi Teknik Perencanaan Pembangkit Listrik Tenaga Surya Sistem Hybrid Pada Atap Kandang Ayam Closed House di Tualang Kabupaten Serdang Bedagai', *TRANSIENT*, vol. 10, no. 2, pp. 345–353, 2021, [Online]. Available: <https://ejournal3.undip.ac.id/index.php/transient>